



Fresh Air Ventilation Fan

FV-15NLFS1 Whisper Fresh Select- 50-150 CFM, in 10 CFM increments) Fresh Air Supply Fan

Architectural Specifications:

Architectural Specifications:

Inline fan shall be remote mount, ENERGY STAR® certified, with no less than customizable from 50 to 150 CFM as certified by HVI at .2 static pressure in inches water gauge. Power consumption shall be no greater than 27.3 Watts and energy efficiency rating shall be no less than 5.49 CFM/Watt at 0.2 static pressure. The motor shall be totally enclosed, four pole condenser type engineered to run continuously. Power rating shall be 120v/60Hz with ENERGY STAR® Most Efficient designation. MERV 13 is a superior filter and is required in many cases by code or IAQ program recommendations. Housing shall be insulated to reduce condensation. Duct diameter shall be no less than 6". Fan shall be UL and cUL listed for tub/shower enclosure when GFCI protected. Brackets shall be provided for joist, truss or suspension installations. Can be used to comply with ASHRAE 62.2, LEED, and CA Title 24.